

IEC**IECEE**

Ref. Certif. No.

CN49692-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Miniature Circuit Breaker

Name and address of the applicant

Huanyu High Tech. Co. , Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Huanyu High Tech. Co. , Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Huanyu High Tech. Co. , Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

HUYU

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DZ47N-63,DZ47N-63H,DZ47e-63,DZ47e-63H,
EXB3-63,EXB3-63H,EXB3e-63,EXB3e-63H;Additional information (if necessary may also be
reported on page 2)

IEC 60898-1:2002(1st Edition) + AMD 1:2002 + AMD 2:2003

A sample of the product was tested and found
to be in conformity withAs shown in the Test Report Ref. No. which
forms part of this Certificate

03601-A-21CB0100-S-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.04,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0063448

DZ47N-63,DZ47N-63H,DZ47e-63,DZ47e-63H, EXB3-63,EXB3-63H,EXB3e-63,EXB3e-63H;
Ui:500V;Uimp:4kV;
Ue: AC220V/380V,AC230V/400V,AC240V/415V(1P);AC220V,AC230V,AC240V(1P+N,2P);
AC380V,AC400V,AC415V(2P,3P,3P+N,4P);
In: 1A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A,50A,63A;
Type of instantaneous tripping current: B,C,D;
DZ47N-63,DZ47e-63,EXB3-63,EXB3e-63:Ics:6kA;Icn:6kA;
DZ47N-63H,DZ47e-63H,EXB3-63H,EXB3e-63H:Ics:7.5kA;Icn:10kA;
DZ47N-63,DZ47e-63,EXB3-63,EXB3e-63:1P,1P+N(One protected pole with a switched
neutral pole),2P,3P,3P+N(Three protected poles with a switched neutral pole),4P;
DZ47N-63H,DZ47e-63H,EXB3-63H,EXB3e-63H:2P(AC220V,AC230V,AC240V).
50/60Hz

Page 1 of 1

Additional information (if necessary)

Date: Aug.04,2021

Signature:

谢肇煦

Xie ZhaoXu