

IEC**IECEE**

Ref. Certif. No.

CN49703-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Switch-disconnector

Name and address of the applicant

Huanyu High Tech. Co., Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Huanyu High Tech. Co., Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Huanyu High Tech. Co., Ltd
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp:6kV;Ui:500V;Ue:AC220V/230V/240V(1P),AC230(2P),
AC380V/400V/415V(2P,3P,4P);Ith:125A;Ie: 20A,25A,32A,40A,50A,63A,80A,100A,125A,
Icw:1.5kA/1s;Icm(peak value):2.5kA;Utilization category: AC-22A,AC-21B; 1P,2P,3P,4P,
50/60Hz

Trademark / Brand (if any)

HUYU

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DZ47H-125,DZ47He-125,EXH3-125,EXH3e-125;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 +
AMD2:2014;IEC 60947-3:2008(3rd Edition) + AMD 1:2012 +
AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-21CB0099-S-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.04,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0063439